

BRE Global Ireland

Notified Body No. 2831

BRE Global Assurance (Ireland) Limited
DCU Alpha, Old Finglas Road
Glasnevin, Dublin, D11 KXN4
Ireland

T: +353 (0) 18824344

E: enquiries@breglobalireland.ie

www.breglobalireland.ie

Certificate of constancy of performance

2831-CPR-F0254

In compliance with Regulation (EU) No. 305/2011 of the European Parliament and of the Council of 9th March 2011 (the Construction Products Regulation or CPR), this certificate applies to the construction product(s)

CWSO-RR-YY Conventional Sounder

(For full product details and conditions of use refer to appendix)

Placed on the market under the name or trade mark of:

KAC Alarm Company Limited
Honeywell House
Skimped Hill Lane
Bracknell, Berkshire
RG12 1EB
United Kingdom

and produced in the manufacturing plant(s):

Honeywell Life Safety Romania S.R.L
Strade Salcâmilor 2 bis
Lugoj
Timis
305500
Romania

This certificate attests that all provisions concerning the assessment and verification of constancy of performance described in Annex ZA of the standard(s)

EN 54-3:2001 + A1:2002 + A2:2006 - Sounders

under system 1 for the performance set out in this certificate are applied and that the factory production control conducted by the manufacturer is assessed to ensure

the constancy of performance of the construction product.

This certificate was first issued on 16 October 2019 and will remain valid as long as neither the harmonised standard, the construction product, the AVCP methods nor the manufacturing conditions in the plant are modified significantly, unless suspended or withdrawn by the notified product certification body.



P Halligan, Certification Engineer

Date of First Issue: 16 October 2019

Date of Issue: 22 November 2021

On behalf of BRE Global Assurance (Ireland) Limited

Issue number 02

To check the validity of this certificate, please contact us on +353 (0) 18824344 or email enquiries@breglobalireland.ie.

BRE Global Ireland

Notified Body No. 2831

BRE Global Assurance (Ireland) Limited
DCU Alpha, Old Finglas Road
Glasnevin, Dublin, D11 KXN4
Ireland
T: +353 (0) 18824344
E: enquiries@breglobalireland.ie
www.breglobalireland.ie

APPENDIX to Certificate of constancy of performance: 2831-CPR-F0254

CWSO-RR-YY Conventional Sounder

Bases:

CSW 19mm shallow back box – white IP21C
CSR 19mm shallow back box – red IP21C
CWW 45mm deep back box – white IP33C
CWR 45mm deep back box – red IP33C

Notes:

1. Type A with CSW / CSR shallow back box, Type B with CWW / CWR deep back box
Where W = White
Where R = Red
2. **RR** indicates red body colour
3. **YY** indicates mounting option. Where S1 = shallow back box (standard fix)
Where S2 = shallow back box (first fix)
Where W1 = deep back box (standard fix)
Where W2 = deep back box (first fix)
4. Meets the requirements of EN54-3: 2001 at the following tones:
 - 1) 554/440, 2Hz (100ms/400ms);
 - 2) 800/970, 1Hz;
 - 3) 800/970, 2Hz;
 - 4) 2400/2900, 3Hz;
 - 5) 2500/3100, 2Hz;
 - 6) 988/645, 2Hz;
 - 7) 660Hz;
 - 8) 970Hz;
 - 9) 1200Hz;
 - 10) 2850Hz;
 - 11) 2400Hz, alternating between frequencies 2400Hz, 3100Hz & 988Hz
 - 12) 420Hz, 0.625s on, 0.625 sec off;
 - 13) 500-1200Hz, 0.25 sec off, 3.75 sec on;
 - 14) 660, 3.33Hz, 150ms on, 150ms off;
 - 15) 970, 0.8Hz 0.25s on, 1s off;
 - 16) 970, 0.5Hz 1s on, 1s off;
 - 17) 2810, 1Hz;

P. Halligan

P Halligan, Certification Engineer,

On behalf of BRE Global Assurance (Ireland) Limited

Date of First Issue: 16 October 2019

Date of issue: 22 November 2021

Issue number: 02

To check the validity of this certificate, please contact us on +353 (0) 18824344 or email enquiries@breglobalireland.ie.

BRE Global Ireland

Notified Body No. 2831

BRE Global Assurance (Ireland) Limited
DCU Alpha, Old Finglas Road
Glasnevin, Dublin, D11 KXN4
Ireland
T: +353 (0) 18824344
E: enquiries@breglobalireland.ie
www.breglobalireland.ie

APPENDIX to Certificate of constancy of performance: 2831-CPR-F0254

- 18) 970, 1Hz 500ms on, 500ms off;
- 19) 950, 0.22Hz (0.5s on, 0.5s off) x 3, 1.5s off;
- 20) 800Hz;
- 21) 400-1200Hz, (0.5s on, 0.5s off) x 3, 1.5s off;
- 22) 1200 – 500Hz, 0.99Hz 1s on, 0.01s off;
- 23) 2400 – 2850, 7Hz;
- 24) 500 – 1200Hz, (0.5s off, 3.5s on);
- 25) 800 – 970, 50Hz;
- 26) 800 – 970, 7Hz;
- 27) 800 – 970, 1Hz;
- 28) 2400 – 2850, 50Hz;
- 29) 500 – 1000, 7Hz;
- 30) 500 – 1200 – 500, 0.166Hz rise 1s, stable 4s, fall 1s;
- 31) 800 – 1000, 2Hz;
- 32) 2400 – 2850, 1Hz;

Variant

CWSO-WW-YY Conventional Sounder
WW= white body

P. Halligan

P Halligan, Certification Engineer,

On behalf of BRE Global Assurance (Ireland) Limited

Date of First Issue: 16 October 2019

Date of issue: 22 November 2021

Issue number: 02

To check the validity of this certificate, please contact us on +353 (0) 18824344 or email enquiries@breglobalireland.ie.