

CERTIFICATE OF CONFORMITY



CoC Number: RAL-900

We declare that the following products: -

RAL900, RAL900M, RAL900DM
Electric Release

have been successfully tested to the following: -

Evidence of Fire Test Compliance

- Fire Test Report CFR2508191 dated 19th August 2025
- Fire tested to EN 1634-1 for 30min Timber Doors on exposed and unexposed side, opening both inward and outward in the Fail Secure mode
- Falcon Strebord Particleboard core with lipping and a glazed aperture 2040 x 1000 x 44mm

EMC Directive 89/336/EEC

- **EN 55032:2015** Electromagnetic compatibility of multimedia equipment
- **EN 61000-3-2:2014** Electrical and Electronic tested that has an input current of up to 16A per phase, suitable for connection to the low-voltage AC public mains distribution network.
- **EN 61000-3-3:2013** Test for limitation of voltage fluctuations and flicker impressed on the public low-voltage system
- **EN 55035:2017+A11:2020** Clarifies the scope and national implementation status for electromagnetic compatibility (EMC) immunity requirements of multimedia equipment

Signed for and on behalf of the manufacturer by:

Kevin O'Reilly - Technical Director
At Rutland UK, Unit 4, Holmewood Business Park,
Chesterfield Road, Chesterfield, S42 5US, UK

on 5-11-2025