

Product Code: SC4411PRO4

Luckinslive 424506481

Description: Astro Bluetooth 1 Channel 7 Day Digital Panel Timer



General Information

Outputs

Dimensions (mm)	94.5 x 72 x 53
Panel Dimensions (mm)	72 x 72
Display	Backlit-LCD Display
Time Base	Quartz Crystal
Quartz Crystal Accuracy (at 20°C)	± 0.5 Seconds / Day
Materials	Self-Extinguishing Thermoplastic
Mounting	Surface or Panel
Switchboard Flush Dimensions (mm)	Retaining clip in 68 x 68 cutout
Warranty (Years)	3

Number of Outputs	1
Relay/Contact Type	SPDT
Total Switch Rating (Inductive)	10A @ 0.6pf
Total Switch Rating (Resistive)	230V AC, 16A @ 1.0pf
Maximum LED Lamp Load Rating (W)	200 @ 230V
Contact Material	AgSnO ²
Maximum Incandescent, Halogen Lamp Load Rating (W)	2000
Maximum Starting Current Rating (A)	50
Maximum Fluorescent Lamp (Uncompensated) Load Rating (W)	1000
Maximum Fluorescent Lamp (Series Compensated) Load Rating (W)	1000
Maximum Fluorescent Lamp (Parallel Compensated) Load Rating (W)	550
Minimum Switching power (mW)	1000 (10V/10mA)

Programming

Programming Schedule	Astro, 24 Hour, and 7 Day Programmable
Bluetooth	Yes
Available Operations	300 Operations
Switching Modes	ON, OFF, Pulse, Cycle, Extra, Permanent, Astro
Minimum Interval (Between 2 Switchings)	1 Minute
Program Security	Unlimited (E2-PROM)
Pulse length - Pulse function (switching time)	00:01 up to 59.59 mm:ss
Pulse length - Timer (man. switching)	0:00:01 up to 9:59:59 h:mm:ss

Supply & Power

Supply Voltage (V AC)	230
Power Consumption (W)	0.2-1
Power Reserve	10 Years (Approx.)
IEC Protection Class	Class II When Installed According to Regulations

Environment

Ingress Protection	IP20
Operating Temperature (°C)	-30 to +55

Features

Volt-free 16A Changeover Contact
300 Memory Locations
Programmable via App (iOS, Android and Windows)
Battery Reserve: 10 years
Comes Ready for Panel or Surface Mounting



Unit 7 Target Park, Shawbank Road,
Lakeside, Redditch B98 8YN United Kingdom
T: +44 (0)1527 515150 | F: +44 (0)1527 515143
E: info@espuk.com | W: espuk.com

CLICK OR SCAN

Catalogue



DoC



Installation



CLICK OR SCAN