



EU Type Examination Certificate Number: 0120/ SGS0212

Shenzhen Clou Electronics Co., Ltd.

16/F, Clou Building Baoshen Road South Hi-tech Industrial Park North Nanshan District Shenzhen, China

Instrument Identification: CL710K22

Instrument Traceable Number 0120/ SGS0212

Single Phase, Active Import/ Export, Outdoor, Electricity Meter

has been assessed and certified as meeting the requirements of

EU Directive 2014/32/EU

on Measuring Instruments Annex II, Module B

It is certified that the manufacturer's technical design and specimen for the above instrument has been examined and, based on the evidence submitted, it is considered that the instrument conforms to the requirements of Annex V of EU Directive 2014/32/EU

This certificate must be used in conjunction with a certificate covering the product verification as required in

Annex II, Module D or Annex II, Module F

This certificate is valid until 11th April 2026 Issue 3

Certification is based on report number(s) SZES151000342001 dated 5 April 2016

Authorised Signature



Contact Address SGS United Kingdom Ltd, Units 12A & 12B, South Industrial Estate, Bowburn, Durham, DH6 5AD□UK t +44 (0)191 377 2000 f +44 (0)191 377 2020 www.sgs.com

This document is issued, on the Client's behalf, by the Company under its General Conditions of Service printed overleaf. The Client's attention is drawn to the limitation of liability, indemnification and jurisdiction issues defined therein.

Any other holder of this document is advised that information contained hereon reflects the Company's findings at the time of its intervention AND ADDE ARE AND IN ITS IN

SGSPAPER^{EU Type} Examination Cert.



0120/SGS0212

Issue Number: 3 Dated: 24th May 2018

1. Technical Data

Manufacturer	Shenzhen Clou Electronics Co., Ltd.
Meter Type	CL710K22
Voltage Rating (Un)	220-240V
Current Rating (Imin – Iref (Imax))	0.05-5(100)A, 0.05-5(80)A
Frequency (Fn)	50/60Hz
Active Accuracy Class (kWh)	C (kWh)
Type of circuit	1p2w
Temperature Range	-40°C to +70°C
Software/ Firmware Version No Identification Location	08 LCD
Bill Of Materials Number	Keyboard:26064696000001 Non-Keyboard:26064696000003
IP Rating	IP54
Insulation Protective Class	Class II
Mechanical Environment	M1
Electromagnetic Environment	E2
LED Pulse Constant	1600 imp/ kWh
Impulse Voltage Rating	6kV
AC Voltage Rating	4kV
Main Cover Sealing Type	Wire & Crimp
Integrity of meter	Inaccessible without breaking seals
Intended Location of the Meter	Outdoor
Type of Register	LCD
Terminal Arrangement(s)	BS



0120/SGS0212

Issue Number: 3

Dated: 24th May 2018

2. Photographs of Meter and Sealing Plan



Main cover seals



0120/SGS0212

Issue Number: 3

Dated: 24th May 2018



Main cover seals



0120/SGS0212


Issue Number: 3

Dated: 24th May 2018

3. Nameplates


PLC Version






RF Version





GPRS Version







0120/SGS0212

Issue Number: 3

Dated: 24th May 2018

4. Influence factors for temperature, frequency and voltage

Current	PF Cos	-40°C	-25°C	-10°C	5°C	30°C	40°C	55°C	70°C
lmin	1.0	0.66	0.41	0.23	0.17	0.09	0.12	0.16	0.19
ltr	1.0	0.64	0.40	0.26	0.13	0.07	0.09	0.17	0.19
10ltr	1.0	0.65	0.41	0.26	0.13	0.03	0.06	0.14	0.15
Imax	1.0	0.47	0.35	0.28	0.23	0.19	0.18	0.17	0.18
ltr	0.5ind	0.57	0.36	0.21	0.13	0.10	0.11	0.19	0.19
10ltr	0.5ind	0.64	0.37	0.24	0.13	0.06	0.08	0.08	0.15
Imax	0.5ind	0.60	0.51	0.46	0.43	0.40	0.39	0.37	0.38
Itr	0.8cap	0.56	0.37	0.22	0.11	0.07	0.10	0.16	0.16
10ltr	0.8cap	0.59	0.38	0.23	0.12	0.04	0.06	0.13	0.14
Imax	0.8cap	0.49	0.39	0.32	0.28	0.25	0.24	0.22	0.23

During the type approval examination the influence factors for temperature, frequency and voltage are determined per load point. The table above represents the sum of the square values per load, determined via the following formula:-

$$\delta e (T, U, f) = \sqrt{(\delta e^2 (T, I, \cos\varphi), \delta e^2 (U, I, \cos\varphi), \delta e^2 (f, I, \cos\varphi))}$$

where

 $\delta e(T, I, \cos \varphi) =$

Additional error due to variation of the temperature at the same load

 $\delta e(U, I, \cos \varphi) =$

Additional error due to variation of the voltage at the same load

 $\delta e(f, I, \cos \varphi) =$

Additional error due to variation of the frequency at the same load



0120/SGS0212

Issue Number: 3

Dated: 24th May 2018

5. Annex of Variants

Product Variant Identification Details:

 Type Designation	Description of meter		
CL710K22	220-240V 0.05-5(80)A 0.05-5(100)A 1p2w Optional detachable communication modules: PLC module, RF module, GPRS module		

Modifications to the meter(s) described according to approval No.0120/ SGS0212 must be notified to the issuing body to confirm the meter(s) continuing compliance to the relevant pattern approval standard(s).



0120/SGS0212

Issue Number: 3 Dated: 24th May 2018

6. Document Revision History

Issue	Date	Comments
1	12/04/2016	Initial Issue
2	19/01/2017	Updated to the requirements of EU Directive 2014/32/EU Mechanical and Electromagnetic environments added to technical data
3	24/05/2018	Optional GPRS communication module

"This document is issued by the Company subject to its General Conditions of Service available on request or accessible at http://www.sgs.com/er/Terms-and-Conditions.aspx and, for electronic format documents, subject to Terms and Conditions for Electronic Documents at www.sgs.com/terms_e-document.htm. Attention is drawn to the limitation of liability, indemnification and jurisdiction issues defined therein. Any holder of this document is advised that information contained hereon reflects the Company's findings at the time of its intervention only and within the limits of Client's instructions, if any. The Company's sole responsibility is to its Client and this document does not exonerate parties to a transaction from exercising all their rights and obligations under the transaction documents. This document cannot be reproduced except in full, without prior written approval of the Company. Any unauthorized alteration, forgery or falsification of the content or appearance of this document is unlawful and offenders may be prosecuted to the fullest extent of the law."

"Unless otherwise stated the results shown in this test certificate refer only to the sample(s) tested and such sample(s) are retained for 28 days

	**	End	of Document	**
--	----	-----	-------------	----