Xnightsbridge

DATASHEET




BATSCWMST4

230V 4ft 18/32W CCT Adjustable Microwave Self-

Test Emergency Batten

www.mlaccessories.co.uk



| MLA PART CODE | BATSCWMST4 |
|-------------------------------|--|
| DESCRIPTION | 230V 4ft 18/32W CCT Adjustable Microwave Self-Test Emergency Batten |
| NET WEIGHT (KG) | 1.6 |
| FINISH | White |
| DIFFUSER | Opal |
| DIMENSIONS (MM) | Length - 1225 Width - 61 Projection - 71 |
| CONSTRUCTION | Construction - Pressed steel Construction 2 - & polycarbonate |
| CLASS | I |
| IP RATING | IP20 |
| WATTAGE (W) | 18/32 |
| LAMP TECHNOLOGY | LED |
| LUMENS (LM) | 2380/2600/2570, 3950/4490/4310 |
| LUMENS LIGHT SOURCE ONLY (LM) | 5020 |
| LUMEN TOLERANCE | 5% |
| EFFICACY (LM/W) | 159.14 |
| LUMENS EMERGENCY MODE (LM) | 320 |
| CIRCUIT WATTAGE (W) | 31.6 |
| ССТ | 3000/4000/5700K |
| LIGHT COLOUR | CCT |
| CRI | >85 |
| SDCM | <6 |
| RUNNING CURRENT (A) | 0.142 |
| DISPLACEMENT FACTOR | >0.7 |
| SVM | 0 |
| PST-LM | 0 |
| BEAM ANGLE (DEGREES) | 145 |





Xnightsbridge

| L70B50 LIFESPAN (HRS) | 60,000 |
|--|--|
| DIMMABLE | No |
| EMERGENCY | Maintained / Non-maintained / Switched |
| SELF-TEST | Yes |
| OPERATING TEMPERATURE | -5~50°C |
| INPUT VOLTAGE | 230V 50Hz |
| CABLE GLAND INCLUDED | No |
| DRIVER | DRIVER TYPE - Constant Current MAX. OUTPUT - 16/31W OUTPUT VOLTAGE - 30-43V OUTPUT CURRENT - 360/720mA POWER FACTOR - 0.95 EFFICIENCY FULL LOAD - 97.1 ISOLATION - SELV AMBIENT TEMPERATURE (Ta)20~50°C CASE TEMPERATURE (Tc) - 75°C |
| SENSOR TYPE | Microwave |
| SENSOR OVERRIDE | No |
| SENSOR DETECTION ANGLE (DEGREES) | 150 (wall mounted) / 360 (ceiling mounted) |
| OPTIMUM DETECTION RANGE (M) | 6m at height 3m, max. mounting height 6m |
| SENSOR DURATION | 5 seconds - 30 minutes |
| SENSOR LUX SETTINGS | 2 lux - 50 lux / Disable |
| BATTERY INCLUDED | Yes |
| STANDBY POWER | ≤ 0.5WW |
| WARRANTY | 5year(s) |
| WARRANTY INFORMATION | (excluding battery) |
| ORIGIN OF MANUFACTURE | China |
| DECLARATION OF CONFORMITY (HELD ON FILE) | Yes |
| EAN | 5056270881660 |

Date Created: 03/04/2023 13:56





